

**EXISTING INVERTER SPLIT A/C UNIT SCHEDULE**

**FAN COIL/AIR-COOLED CONDENSING UNIT SCHEDULE**

MARK	DESCRIPTION	LOCATION	NOMINAL COOLING (HP)	REFRIGERANT	ELECTRICAL		REMARKS
					V-PH-HZ	HACR BRKR	
FCU-COB-1/ACCU-COB-1	WALL MOUNTED TYPE, STRAIGHT COOL	HEA'S OFFICE	1.5	R-410A	220-1-60	15 A	SEE NOTES
FCU-COB-2/ACCU-COB-2	WALL MOUNTED TYPE, STRAIGHT COOL	EXECUTIVE SECRETARY OFFICE	1.5	R-410A	220-1-60	15 A	SEE NOTES
FCU-COB-3/ACCU-COB-3	WALL MOUNTED TYPE, STRAIGHT COOL	PRESIDENT/CEO OFFICE	2.0	R-410A	220-1-60	20 A	SEE NOTES
FCU-COB-4/ACCU-COB-4	WALL MOUNTED TYPE, STRAIGHT COOL	AVP OFFICE	1.5	R-410A	220-1-60	15 A	SEE NOTES
FCU-COB-5/ACCU-COB-5	WALL MOUNTED TYPE, STRAIGHT COOL	STAFF OFFICE	1.0	R-410A	220-1-60	15 A	SEE NOTES
FCU-COB-6/ACCU-COB-6	WALL MOUNTED TYPE, STRAIGHT COOL	EVP/COO SECRETARY OFFICE	1.5	R-410A	220-1-60	15 A	SEE NOTES
FCU-COB-7/ACCU-COB-7	WALL MOUNTED TYPE, STRAIGHT COOL	AOCS OFFICE	1.5	R-410A	220-1-60	15 A	SEE NOTES
FCU-COB-8/ACCU-COB-8	WALL MOUNTED TYPE, STRAIGHT COOL	RMO	1.0	R-410A	220-1-60	15 A	SEE NOTES
FCU-COB-9/ACCU-COB-9	WALL MOUNTED TYPE, STRAIGHT COOL	VIP LOUNGE	1.5	R-410A	220-1-60	15 A	SEE NOTES
FCU-COB-10/ACCU-COB-10	WALL MOUNTED TYPE, STRAIGHT COOL	VIP LOUNGE	1.5	R-410A	220-1-60	15 A	SEE NOTES
FCU-COB-11/ACCU-COB-11	CEILING CASSETTE TYPE, STRAIGHT COOL	BOARD ROOM	4.0	R-410A	220-1-60	30 A	SEE NOTES
FCU-COB-12/ACCU-COB-12	CEILING CASSETTE TYPE, STRAIGHT COOL	BOARD ROOM	4.0	R-410A	220-1-60	30 A	SEE NOTES
FCU-COB-13/ACCU-COB-13	WALL MOUNTED TYPE, STRAIGHT COOL	DIRECTOR'S LOUNGE	1.5	R-410A	220-1-60	15 A	SEE NOTES
FCU-COB-14/ACCU-COB-14	WALL MOUNTED TYPE, STRAIGHT COOL	TREASURY MANAGER OFFICE	1.5	R-410A	220-1-60	15 A	SEE NOTES
FCU-COB-15/ACCU-COB-15	WALL MOUNTED TYPE, STRAIGHT COOL	TREASURY OFFICE	2.5	R-410A	220-1-60	15 A	SEE NOTES
FCU-COB-16/ACCU-COB-16	CEILING CASSETTE TYPE, STRAIGHT COOL	FINANCE STAFF OFFICE	4.0	R-410A	220-1-60	30 A	SEE NOTES
FCU-COB-17/ACCU-COB-17	CEILING CASSETTE TYPE, STRAIGHT COOL	ACCOUNTING STAFF OFFICE	4.0	R-410A	220-1-60	30 A	SEE NOTES
FCU-COB-18/ACCU-COB-18	WALL MOUNTED TYPE, STRAIGHT COOL	LEGAL MANAGER OFFICE	1.0	R-410A	220-1-60	15 A	SEE NOTES
FCU-COB-19/ACCU-COB-19	WALL MOUNTED TYPE, STRAIGHT COOL	FINANCE MANAGER OFFICE	1.0	R-410A	220-1-60	15 A	SEE NOTES
FCU-COB-20/ACCU-COB-20	WALL MOUNTED TYPE, STRAIGHT COOL	PROVIDENT OFFICE	1.0	R-410A	220-1-60	15 A	SEE NOTES
FCU-COB-21/ACCU-COB-21	WALL MOUNTED TYPE, STRAIGHT COOL	INTERNAL AUDIT	1.5	R-410A	220-1-60	15 A	SEE NOTES
FCU-COB-22/ACCU-COB-22	WALL MOUNTED TYPE, STRAIGHT COOL	COA OFFICE	2.5	R-410A	220-1-60	20 A	SEE NOTES
FCU-COB-23/ACCU-COB-23	CEILING CASSETTE TYPE, STRAIGHT COOL	PRESIDENT RECEPTION LOBBY	4.0	R-410A	220-1-60	30 A	SEE NOTES
FCU-COB-24/ACCU-COB-24	CEILING CASSETTE TYPE, STRAIGHT COOL	RECEPTION LOBBY	4.0	R-410A	220-1-60	30 A	SEE NOTES
FCU-COB-25/ACCU-COB-25	WALL MOUNTED TYPE, STRAIGHT COOL	PRAYER ROOM	1.0	R-410A	220-1-60	15 A	SEE NOTES
FCU-COB-26/ACCU-COB-26	WALL MOUNTED TYPE, STRAIGHT COOL	DATA ROOM	1.5	R-410A	220-1-60	15 A	SEE NOTES
FCU-COB-27/ACCU-COB-27	WALL MOUNTED TYPE, STRAIGHT COOL	PROCUREMENT MANAGER	1.5	R-410A	220-1-60	15 A	SEE NOTES
FCU-COB-28/ACCU-COB-28	WALL MOUNTED TYPE, STRAIGHT COOL	MIS OFFICE	1.0	R-410A	220-1-60	20 A	SEE NOTES
FCU-COB-29/ACCU-COB-29	WALL MOUNTED TYPE, STRAIGHT COOL	DR ROOM	1.0	R-410A	220-1-60	15 A	SEE NOTES
FCU-COB-30/ACCU-COB-30	WALL MOUNTED TYPE, STRAIGHT COOL	CLINIC	1.5	R-410A	220-1-60	15 A	SEE NOTES
FCU-COB-31/ACCU-COB-31	WALL MOUNTED TYPE, STRAIGHT COOL	VP-AOMG STAFF OFFICE	2.5	R-410A	220-1-60	20 A	SEE NOTES

**EXISTING INVERTER SPLIT A/C UNIT SCHEDULE**

**FAN COIL/AIR-COOLED CONDENSING UNIT SCHEDULE**

MARK	DESCRIPTION	LOCATION	NOMINAL COOLING (HP)	REFRIGERANT	ELECTRICAL		REMARKS
					V-PH-HZ	HACR BRKR	
FCU-COB-32/ACCU-COB-32	WALL MOUNTED TYPE, STRAIGHT COOL	VP-AOMG OFFICE	3.0	R-410A	220-1-60	20 A	SEE NOTES
FCU-COB-33/ACCU-COB-33	WALL MOUNTED TYPE, STRAIGHT COOL	HRD MANAGER OFFICE	1.0	R-410A	220-1-60	15 A	SEE NOTES
FCU-COB-34/ACCU-COB-34	WALL MOUNTED TYPE, STRAIGHT COOL	HRD STAFF OFFICE	1.5	R-410A	220-1-60	20 A	SEE NOTES
FCU-COB-35/ACCU-COB-35	WALL MOUNTED TYPE, STRAIGHT COOL	HRD STAFF OFFICE	2.5	R-410A	220-1-60	20 A	SEE NOTES
FCU-COB-36/ACCU-COB-36	WALL MOUNTED TYPE, STRAIGHT COOL	OCC OFFICE	2.0	R-410A	220-1-60	20 A	SEE NOTES
FCU-COB-37/ACCU-COB-37	WALL MOUNTED TYPE, STRAIGHT COOL	OCC OFFICE	2.0	R-410A	220-1-60	20 A	SEE NOTES
FCU-COB-38/ACCU-COB-38	CEILING CASSETTE TYPE, STRAIGHT COOL	ENGINEERING/PLANNING OFFICE	4.0	R-410A	220-1-60	25 A	SEE NOTES
FCU-COB-39/ACCU-COB-39	CEILING CASSETTE TYPE, STRAIGHT COOL	ENGINEERING/PLANNING OFFICE	4.0	R-410A	220-1-60	25 A	SEE NOTES
FCU-COB-40/ACCU-COB-40	WALL MOUNTED TYPE, STRAIGHT COOL	ENGINEERING CONFERENCE ROOM	2.0	R-410A	220-1-60	20 A	SEE NOTES
FCU-COB-41/ACCU-COB-41	WALL MOUNTED TYPE, STRAIGHT COOL	MARKETING CONFERENCE ROOM	1.5	R-410A	220-1-60	15 A	SEE NOTES
FCU-COB-42/ACCU-COB-42	WALL MOUNTED TYPE, STRAIGHT COOL	MARKETING OFFICE	1.5	R-410A	220-1-60	15 A	SEE NOTES
FCU-COB-43/ACCU-COB-43	CEILING CASSETTE TYPE, STRAIGHT COOL	PROCUREMENT STAFF	4.0	R-410A	220-1-60	25 A	SEE NOTES
FCU-COB-44/ACCU-COB-44	CEILING CASSETTE TYPE, STRAIGHT COOL	MARKETING STAFF	4.0	R-410A	220-1-60	25 A	SEE NOTES
FCU-COB-45/ACCU-COB-45	WALL MOUNTED TYPE, STRAIGHT COOL	MIS OFFICE	1.0	R-410A	220-1-60	15 A	SEE NOTES
FCU-COB-46/ACCU-COB-46	WALL MOUNTED TYPE, STRAIGHT COOL	VP-CBDG OFFICE	2.0	R-410A	220-1-60	20 A	SEE NOTES
FCU-COB-47/ACCU-COB-47	WALL MOUNTED TYPE, STRAIGHT COOL	VP-CBDG SECRETARY OFFICE	1.0	R-410A	220-1-60	15 A	SEE NOTES
FCU-COB-48/ACCU-COB-48	WALL MOUNTED TYPE, STRAIGHT COOL	VP-FINANCE SECRETARY OFFICE	1.0	R-410A	220-1-60	15 A	SEE NOTES
FCU-COB-49/ACCU-COB-49	WALL MOUNTED TYPE, STRAIGHT COOL	VP-FINANCE OFFICE	1.5	R-410A	220-1-60	15 A	SEE NOTES
FCU-COB-50/ACCU-COB-50	WALL MOUNTED TYPE, STRAIGHT COOL	ATO	1.0	R-410A	220-1-60	15 A	SEE NOTES
FCU-COB-51/ACCU-COB-51	WALL MOUNTED TYPE, STRAIGHT COOL	ATO SECRETARY	1.0	R-410A	220-1-60	15 A	SEE NOTES
FCU-COB-52/ACCU-COB-52	FLOOR MOUNTED TYPE, STRAIGHT COOL	EQUIPMENT ROOM	5.0(TR)	R-410A	220-3-60	40 A	SEE NOTES
FCU-COB-53/ACCU-COB-53	FLOOR MOUNTED TYPE, STRAIGHT COOL	EQUIPMENT ROOM	5.0(TR)	R-410A	220-3-60	40 A	SEE NOTES
FCU-COB-54/ACCU-COB-54	FLOOR MOUNTED TYPE, STRAIGHT COOL	MAINTENANCE ROOM	3.0(TR)	R-410A	220-1-60	30 A	SEE NOTES
FCU-COB-55/ACCU-COB-55	FLOOR MOUNTED TYPE, STRAIGHT COOL	MAINTENANCE ROOM	3.0(TR)	R-410A	220-1-60	30 A	SEE NOTES
FCU-COB-56/ACCU-COB-56	CEILING MOUNTED TYPE, STRAIGHT COOL	UPS ROOM	2.0(TR)	R-410A	220-1-60	25 A	SEE NOTES
FCU-COB-57/ACCU-COB-57	CEILING MOUNTED TYPE, STRAIGHT COOL	UPS ROOM	2.0(TR)	R-410A	220-1-60	25 A	SEE NOTES
FCU-COB-58/ACCU-COB-58	CEILING CASSETTE TYPE, STRAIGHT COOL	RADAR OPERATION ROOM	3.0(TR)	R-410A	220-1-60	30 A	SEE NOTES
FCU-COB-59/ACCU-COB-59	CEILING CASSETTE TYPE, STRAIGHT COOL	RADAR OPERATION ROOM	3.0(TR)	R-410A	220-1-60	30 A	SEE NOTES
FCU-COB-60/ACCU-COB-60	CEILING CASSETTE TYPE, STRAIGHT COOL	RADAR OPERATION ROOM	3.0(TR)	R-410A	220-1-60	30 A	SEE NOTES
FCU-COB-61/ACCU-COB-61	CEILING CASSETTE TYPE, STRAIGHT COOL	RADAR OPERATION ROOM	3.0(TR)	R-410A	220-1-60	30 A	SEE NOTES
FCU-COB-62/ACCU-COB-62	CEILING CASSETTE TYPE, STRAIGHT COOL	ATC LOCKER ROOM	3.0(TR)	R-410A	220-1-60	30 A	SEE NOTES

**EXISTING INVERTER SPLIT A/C UNIT SCHEDULE**

**FAN COIL/AIR-COOLED CONDENSING UNIT SCHEDULE**

MARK	DESCRIPTION	LOCATION	NOMINAL COOLING (HP)	REFRIGERANT	ELECTRICAL		REMARKS
					V-PH-HZ	HACR BRKR	
FCU-COB-63/ACCU-COB-63	FLOOR MOUNTED TYPE, STRAIGHT COOL	CORPORATE PLANNING	3.0(TR)	R-410A	220-1-60	30 A	SEE NOTES
FCU-COB-64/ACCU-COB-64	WALL MOUNTED TYPE, STRAIGHT COOL	CHIEF ANS. OFFICE	1.0	R-410A	220-1-60	15 A	SEE NOTES
FCU-COB-65/ACCU-COB-65	WALL MOUNTED TYPE, STRAIGHT COOL	EMPTY ROOM	1.0	R-410A	220-1-60	15 A	SEE NOTES
FCU-COB-66/ACCU-COB-66	WALL MOUNTED TYPE, STRAIGHT COOL	HRD STORAGE ROOM	1.0	R-410A	220-1-60	15 A	SEE NOTES
FCU-COB-67/ACCU-COB-67	WALL MOUNTED TYPE, STRAIGHT COOL	MIS EQUIPMENT ROOM	2.0	R-410A	220-1-60	20 A	SEE NOTES
FCU-COB-68/ACCU-COB-68	WALL MOUNTED TYPE, STRAIGHT COOL	MIS EQUIPMENT ROOM	2.0	R-410A	220-1-60	20 A	SEE NOTES
FCU-COB-69/ACCU-COB-69	FLOOR MOUNTED TYPE, STRAIGHT COOL	CENTRAL RECORDS ROOM	7.5(TR)	R-410A	220-1-60	50 A	SEE NOTES
FCU-COB-70/ACCU-COB-70	WALL MOUNTED TYPE, STRAIGHT COOL	BOARD ROOM	2.0	R-410A	220-1-60	20 A	SEE NOTES
FCU-COB-71/ACCU-COB-71	WALL MOUNTED TYPE, STRAIGHT COOL	BOARD ROOM	2.0	R-410A	220-1-60	20 A	SEE NOTES



**NEW INVERTER SPLIT A/C UNIT SCHEDULE**

**FAN COIL/AIR-COOLED CONDENSING UNIT SCHEDULE**

MARK	DESCRIPTION	LOCATION	NOMINAL COOLING (HP)	REFRIGERANT	ELECTRICAL		REMARKS
					V-PH-HZ	HACR BRKR	
FCU-COB-72/ACCU-COB-72	WALL MOUNTED TYPE, STRAIGHT COOL	VIP LOUNGE	2.5	R-410A	220-1-60	20 A	SEE NOTES
FCU-COB-73/ACCU-COB-73	WALL MOUNTED TYPE, STRAIGHT COOL	RMO MANAGER OFFICE	1.5	R-410A	220-1-60	15 A	SEE NOTES
FCU-COB-74/ACCU-COB-74	CEILING MOUNTED TYPE, STRAIGHT COOL	CENTRAL RECORD'S ROOM	5(TR)	R-410A	220-1-60	40 A	SEE NOTES
FCU-COB-75/ACCU-COB-75	CEILING MOUNTED TYPE, STRAIGHT COOL	CENTRAL RECORD'S ROOM	5(TR)	R-410A	220-1-60	40 A	SEE NOTES
FCU-COB-76/ACCU-COB-76	WALL MOUNTED TYPE, STRAIGHT COOL	MIS EXTENSION ROOM	2.0	R-410A	220-1-60	20 A	SEE NOTES
FCU-COB-77/ACCU-COB-77	WALL MOUNTED TYPE, STRAIGHT COOL	MIS EXTENSION ROOM	2.0	R-410A	220-1-60	20 A	SEE NOTES
FCU-COB-78/ACCU-COB-78	WALL MOUNTED TYPE, STRAIGHT COOL	EMD MANAGER OFFICE	1.0	R-410A	220-1-60	15 A	SEE NOTES

**NOTES:**

1. PROVIDE CONDENSING UNIT WITH MANUFACTURER'S COATED COILS, THERMAL OVERLOAD PROTECTION, TIME DELAY AND OVER VOLTAGE PROTECTION.
2. PROVIDE FAN COIL UNIT WITH MICROPROCESSOR CONTROLLER ABLE TO INTERFACE WITH BUILDING MANAGEMENT SYSTEM
3. FAN COIL UNIT WITH HAND HELD REMOTE CONTROL OPTION.
4. LOCATE CONDENSING UNIT ON 6" THK. CONCRETE PAD.
5. CENTRAL CONTROLLER/BMS SHALL CONTROL UNIT TEMPERATURE AND HUMIDITY SETTINGS, TIME OF OPERATION, AND STATUS.

	PROJECT / LOCATION:	DESIGN STAFF:	RECOMMENDING APPROVAL:	APPROVED BY:	REMARKS/REVISED:	DISCIPLINE:	SHEET NO.:
	IMPROVEMENT CORPORATE BUILDING CIVIL AVIATION COMPLEX, CLARK FREEPORT ZONE, PAMPANGA	GBLN II	FEDERICO G. GARCIA Jr. OIC - EMD	DAN A. BAUTISTA VP-OPERATION MANAGEMENT GROUP		ARCHITECTURAL	
						EXISTING INVERTER SPLIT A/C UNIT SCHEDULE NEW INVERTER SPLIT A/C UNIT SCHEDULE	